



INTERTEK TESTING SERVICES  
 SHENZHEN LTD. GUANGZHOU BRANCH  
 Block E, No.7-2 Guang Dong Software Science Park,  
 Caipin Road, Guangzhou Science City, GETDD,  
 Guangzhou, China 510663

**Intertek Report No. GZ12061546-1R1**  
**Supersede Report No. GZ12061546-1 dated July 9, 2012.**

EVALUATION  
 OF

**Model K200, BC. DA. POWER ADJ. PT1 Door Closer  
 FOR**

**SAMHWA PRECISION CO., LTD**  
 SIWHA INDUSTRIAL COMPLEX 2-NA-601, 1262, JEONGWANG DONG,  
 SIHEUNG-SHI, GYENGGI-DO, KOREA

**TEST STANDARD:**

Per customer's specifications, using the following standard as a guideline: ANSI/BHMA A156.4 - 2008 American National Standard for Door Controls- Closers.

**TEST SAMPLES:**

Samples were identified by the applicant as Model K200, BC. DA. POWER ADJ. Size 1 to 6, PT1 and Optional Features PT4C, PT4D, PT4F, PT4H. Samples were received in good condition on June 25, 2012 and January 1, 2013, which manufactured by SAMHWA PRECISION CO., LTD.

**TEST DATES:**

From: June 25, 2012 to Aug 8, 2013

**RESULTS:**


<u>Subsection</u>	<u>Test Description</u>	<u>Initial Test Results</u>	<u>Retest Test Results</u>
4	Initial Static Test	Compliant	Compliant
5, 6	Intermediate Cycle and Static Test	Compliant	Compliant
7, 8	Final Cycle Test and Static Test	Noncompliant	Compliant
10	Finish Tests	Not test	Compliant

The attached summary and data are results of the product testing and evaluation.


**Amendment 1:**

The original Report Reference No. GZ112061546-1, dated July 9, 2012 modified on August 1, 2013 to update test data form section 1 to 8, and 10.

Report Prepared By:

  
 Credy Chen  
 Engineer  
 Intertek

Reviewed By:

  
 Blusea Dong  
 Technical Team Leader  
 Intertek

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.